

## **Substrates**

### **Description**

Decoplast Wall Systems have been designed to be installed over many approved substrates. The following substrates have been tested and approved by the manufacturer.

### **Materials**

### **Specification**

#### **Durock (or equal):**

Framing not to allow deflections greater than 1/360 live or dead load

#### **Eterspan:**

Must be primed prior to installation

#### **Dens-Glass:**

Must be dry, clean and free of foreign materials

#### **Ext. Grade Plywood:**

Must be 1/2" thick minimum, 4 ply APA exposure or Grade C-D or better

#### **3.4 Self-Furring Metal Lath:**

For retrofit use only; see a Decoplast representative for adhesive instruction

#### **Stucco:**

Must be free of dirt and loose materials, should be unpainted

#### **Brick (Terra Cotta):**

Must be free from release agents, oils or parafants  
No variations in excess of 1/4" in a 4ft. radius

#### **Poured on Precast Concrete:**

Must be clean and plumb with no variations in excess of 1/4" in a 4ft. radius

#### **Concrete Block:**

Must meet Fed. Std. SS-L-30D, ASTM C-630

#### **Ext. Grade Gypsum:**

Must meet Fed Std. SS-L-30D, Type II, Grade W, Class 2; ASTM C-79

**Note:** Any questionable surfaces should be tested by adhesively applying a 1 ft. x 1 ft. EPS foam board. After 3 days, a pull test should be performed. Failure should occur within the EPS foam and not within the adhesive. Consult your Decoplast professional for further information.

#### **Disclaimer**

Decoplast, Inc. will not be held liable for incidental and consequential damages, directly or indirectly sustained, nor for any loss caused by application of these goods not in accordance with current manufacturers instructions or other than the intended use. Our liability is expressly limited to replacement of defective goods only. Any claim will be considered waived unless made in writing to us within thirty days from the date it was discovered.

**Decoplast, Inc.®**

(516) 354-4397 • [www.decoplast.com](http://www.decoplast.com)

352 Franklin Ave, Franklin Square, New York, 11010